

Office of the Joint Director Fire & Emergency Services
Jammu Range, Jammu

The Principal
The Calliope School Doomi Akhnoor Road
Near Forest Guard Training Centre Office
Jammu

No: JDJF&ES/FP/ 3959

Sub: Fire Safety Certificate.

Ref: Your online submission Letter dated: 25.06.2022.

Sir,

Dated: 19-07-2022

The inspection of above said school was got carried out by the inspecting officer of this department. During inspection it was found that the management has installed First Aid Fire Extinguishers in their school premises, besides this one underground water storage tank of 20 KL capacity tank is also available. The school is about 17 Km away from Fire and Emergency Station Canal Jammu and is approachable for fire appliances in case of any emergency. Since the school is already functioning, as such, the management can proceed ahead for operation subject to adopt the following fire safety precautionary measures in letter and spirit forthwith:-

1. 01 No. Clean Agent Type Fire Extinguisher of 02 Kg capacity should be provided in computer room in addition to already existing fire extinguishers.
2. All exits/entrances should be kept open and free from any obstruction for easy and safe evacuation of inmates during any emergency.
3. First Aid Fire fighting system installed in the school building should be checked periodically. Staff and students should be fully trained in handling / operating of fire fighting system installed in the school building. The management shall intimate this office in writing after each quarter that the fire fighting equipments installed in the school are functioning.
4. All class rooms and examination halls having seating capacity for more than 45 students need to be provided with two exits.
5. The corridor of the building shall not be used for any kind of storage.
6. No Hazardous material should be kept inside of the school premises (especially LPG cylinder, Petrol and Diesel etc.). Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.
7. The management of the school shall be wholly and solely responsible for keeping the fire fighting system in working condition 24x7 and safe evacuation of its students during any mishap.
8. At present school is having two blocks, one is double storied and another is single storied concrete buildings. As such no addition / alteration should be made by the school management in the existing structure without prior permission from this department. Any deviation found in this regard, this clearance will be treated withdrawn/cancelled.