

Office of the Food Analyst, Food Laboratory, Jammu

No.: FSSAI/J/ 6425

Dated:- 06-03-23

Subject:- Analytical report of the sample of Water(01)
The analytical report of the sample of Water received from the Calliope School Malpur Dhoomi National Highway Akhnor on 03/03/23 is as under:-

S.NO.	Quality Characteristics	Name of the Method of test used	Result	Prescribed Standards as per (a) Food safety and standards (Food Products and food Additives) regulations 2011 (b) As per label declaration for proprietary foods. © As per Provisions of the Act, Rules & regulations for both the above.
1.	Suspended Impurities	Physical Appearance	Absent	Absent
2.	Colour	DO	Agreeable	Not more than 5 Hazen units/True colour units
3.	Odour	Organoleptic Method	Agreeable	Agreeable
4.	Total Dissolved solids	Gravimetric Method	136.0mg/Litre	Not More than 500mg/litre
5.	Residual free Chlorine	Chemical method	Absent	Not more than 0.2 mg/Litre
6.	Chlorides (as Cl)	Titration method (BIS)	28.36mg/Litre	Not more than 200 mg/Litre
7.	Alkalinity (as Hco3)	DO	136.0mg/Litre	Not more than 200 mg/Litre
8.	PH	PH Meter	7.0	6.5-8.5
9.	Turbidity	Turbidity Meter	0NTU	Not more than 2 Nephelometric turbidity unit (NTU)
Microbiological parameter:-				
1.	Aerobic/Mesophilic/plate count	Fssai Manual	Less than the prescribed limit	Not more than 1x10 ⁶ CFU/ML
2.	Yeast & Mould	Fssai Manual	Absent	Absent
3.	Coliform	Fssai Manual	Absent	Absent

Opinion:- The sample conforms to the standards prescribed for the Drinking water falling under Regulation No. 2.10.9(2) of Food Safety and Standards (Food Products Standards and Food Additives) Regulations 2011 read with Indian Standard IS-10500.


FOOD ANALYST
JAMMU & KASHMIR
Food Analyst
Food Laboratory
Jammu